


TEST REPORT EN 60998-2-1:2004 and IEC 60998-2-1:2002 Connecting devices for low voltage circuits for household and similar purposes Part 2-1: Particular requirements for connecting devices as separate entities with screw-type clamping units	
Report Reference No.	SZES161100451701
Tested by (name + signature)	Rick Lin 
Approved by (name + signature)	Megan Xue 
Date of issue	2016-11-29
Number of pages	13 Pages
Testing laboratory name	SGS-CSTC Standards Technical Services Co., Ltd. Shenzhen Branch
Address	No. 1 Workshop, M-10, Middle Section, Science & Technology Park, Shenzhen, Guangdong, China 518057
Applicant's name	Zhongshanshi henlanzheng ousaimeijiadengshichang
Address	Zhongshanshi henlanzheng sanshaxianganshichang
Test specification: Standard	
IEC 60998-2-1:2002 (see also IEC 60998-1:2002) EN 60998-2-1:2004 (see also EN 60998-1:2004)	
Test procedure	SGS-CSTC
Non-standard test method	N/A
Test Report Form No.	IECEN60998_2_1A
TRF originator.	KEMA
Master TRF	2004-07
Copyright © 2004 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. <i>If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.</i> This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	



Procedure deviation	N/A
Type of test object	Terminal block
Trademark	
Model/type reference	L656
Manufacturer	Same as applicant
Rating	250 V, 3 x 1,5 mm ² T80

Test item particulars:

Number of terminals.....:	<input type="checkbox"/> single	<input checked="" type="checkbox"/> multiway		
Function.....:	<input checked="" type="checkbox"/> junction	<input type="checkbox"/> tapping <input type="checkbox"/> junction and tapping		
Protection against electric shock.....:	<input checked="" type="checkbox"/> with	<input type="checkbox"/> without		
Means of fixing.....:	<input checked="" type="checkbox"/> with	<input type="checkbox"/> without		
IP number.....:	IP 44			
Ambient temperature.....:	<input type="checkbox"/> without T marking	<input checked="" type="checkbox"/> with T marking (°C):100		
Type of terminals, screw-type.....:	<input checked="" type="checkbox"/> pillar	<input type="checkbox"/> saddle		
	<input type="checkbox"/> screw	<input type="checkbox"/> mantle		
	<input type="checkbox"/> stud	<input checked="" type="checkbox"/> unprepared		
Rated connecting capacity (mm²).....:	<input type="checkbox"/> 0,5 mm²	<input type="checkbox"/> 0,75 mm²	<input type="checkbox"/> 1 mm²	<input checked="" type="checkbox"/> 1,5 mm²
	<input type="checkbox"/> 2,5 mm²	<input type="checkbox"/> 4 mm²	<input type="checkbox"/> 6 mm²	<input type="checkbox"/> 10 mm²
	<input type="checkbox"/> 16 mm²	<input type="checkbox"/> 25 mm²	<input type="checkbox"/> 35 mm²	
Type of conductor.....:	<input checked="" type="checkbox"/> rigid	<input checked="" type="checkbox"/> flexible		
Rated voltage (V a.c. / V d.c.).....:	<input checked="" type="checkbox"/> AC	<input type="checkbox"/> DC		

Copy of marking plate and summary of test results (information/comments):



L656

IP44 3×1,5mm²

T80 250V

Summary of testing:

Terminal block L656 was subjected to the full tests and all clauses were found to be in compliance with the requirements of standards.

Possible test case verdicts:

- test case does not apply to the test object.....: **N(/A)**
- test object does meet the requirement.....: **P(ass)**
- test object does not meet the requirement.....: **F(ail)**

Testing

Date of receipt of test item: 2016-11-18

Date (s) of performance of tests: 2016-11-10 – 2016-11-29

General remarks:

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IEC 60998-2.

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.


"(see appended table)" refers to a table appended to the report.

Throughout this report a ☒ comma or ☐ point is used as the decimal separator.

The products may be manufactured in the following factory locaion:

Zhongshanshi henlanzheng ousaimeijiadengshichang

Zhongshanshi henlanzheng sanshaxianganshichang

EN 60 998-2-1:2004 and IEC 60 998-2-1:2002			
Cl.	Requirement - Test	Result - Remark	Verdict
8	MARKING		
8.1	On main part:		
	a) rated connecting capacity (mm ²)	3x1,5 mm ²	P
	b) rated insulation voltage (V)	450 V	P
	c) T marking (°C) (if > 40 °C or < -5 °C)	T80	P
	d) type reference	L656	P
	e) manufacturer's or responsible vendor's name, trademark or identification mark		P
	f) IP if > IP20	IP44	P
	Type of acceptable conductor "r" or "f"		N/A
	Small devices: only d) and e) indicated on device		N/A
	All marks visible on smallest package unit		N/A
8.2	Multiway terminal devices: at least two adjacent		P
8.4	Marking: durable and easily legible; 15 s water; 15 s hexane	Marking moulded	P
9	PROTECTION AGAINST ELECTRIC SHOCK		
	Live parts not accessible		P
10	CONNECTION OF CONDUCTORS		
10.1	Connecting devices allow correct connection of conductors		P
10.101	Terminals accept two or more conductors and		P
	accept rigid and/or flexible unprepared conductors		P
10.102	Each terminal accepts conductors (table 101) and provides the connection of at least two successive smaller cross-sectional areas:		
	Rated connecting capacity (mm ²)	1,5	
	Suitable for connecting cross-sectional areas (mm ²)	0,75, 1,0, 1,5	P

EN 60 998-2-1:2004 and IEC 60 998-2-1:2002			
Cl.	Requirement - Test	Result - Remark	Verdict
10.103	Terminals accept rigid and flexible conductors (table 101), unless otherwise specified (see 8.1)		P
	Smallest diameter (mm); largest diameter (mm):	1,3 mm, 1,8 mm	
	Tightened and loosened 5 times; torque (Nm); table number	0,4 Nm	
	During the test: terminals show no damage		P
10.104	Terminals clamp the conductor without undue damage:		
	Smallest cross-sectional area (mm ²); height H (mm); mass (kg).....:	0,75 mm ² and 260 mm with 0,4 kg	
	Largest cross-sectional area (mm ²); height H (mm); mass (kg).....:	1,5 mm ² and 260 mm with 0,4 kg	
	Torque: as 10.103; during the test: the conductor does not slip out, no break near clamping unit and no damage	0,4 Nm	P
10.105	Pull test:		
	- min. cross-sectional area (mm ²); pull (N)	0,75 mm ² , 30 N	
	- max. cross-sectional area (mm ²); pull (N)	1,5 mm ² , 40 N	
	- torque (Nm) (table 102)	0,4 Nm	
	- during the test the conductor does not come out		P
10.106	Rigid conductor: rated cross-sectional area (mm ²) :	1,5 mm ²	
	Flexible conductor: rated cross-sectional area (mm ²).....:	1,5 mm ²	
	Torque: as 10.103; after the test no wire of the conductor escaped	0,4 Nm	P

EN 60 998-2-1:2004 and IEC 60 998-2-1:2002			
Cl.	Requirement - Test	Result - Remark	Verdict
11	CONSTRUCTION		
11.2	Clamping units clamp conductors reliably and between metal surfaces		P
11.3	Connecting devices: insulation of conductors not in contact with live parts of different polarity		P
11.4	Insulating lining: adequate mechanical strength and secured in a reliable manner		P
11.5	Current-carrying parts: adequate mechanical strength, electrical conductivity and resistance to corrosion; type of metal	Copper: $\geq 58\%$	P
	Current-carrying parts not made with electroplated coating if subjected to mechanical wear		P
11.6	Terminals: possible to connect number of conductors as specified by the manufacturer:		
	- number of conductors.....	1	
	- rigid, cross-sectional area (mm ²)	0,75, 1,0, 1,5	
	- flexible, cross-sectional area (mm ²)	0,75, 1,0, 1,5	
11.7	Fixing means of bases do not serve any other purpose		P
11.101	Screws and nuts of earthing terminals adequately locked against accidental loosening		P
	Not possible to loosen without a tool		P
11.102	Screws and nuts do not serve to fix any other component, and		P
	are not of metal which is soft, such as zinc or aluminium		P
11.103	Rigid wire or wire of flexible conductor cannot slip out		P
11.104	Terminals permit insertion of largest conductor:		
	- rigid conductors: cross-sectional area (mm ²); max. diameter (mm)	1,7	P
	- flexible conductors: cross-sectional area (mm ²); max. diameter (mm)	1,8	P

EN 60 998-2-1:2004 and IEC 60 998-2-1:2002			
Cl.	Requirement - Test	Result - Remark	Verdict
12	RESISTANCE TO AGEING, TO HUMIDITY CONDITIONS, TO INGRESS OF SOLID OBJECTS AND TO HARMFUL INGRESS OF WATER		
12.1	Connecting devices resistant to ageing; after the test (168 h): no cracks visible, not sticky or greasy, no damage; test temperature (°C)	<input type="checkbox"/> 70 °C <input checked="" type="checkbox"/> T + 30 °C = 110	P
12.2	After humidity test (91-95%): no damage; test duration (168 h for connecting devices > IPx2, 48 h for all other)	<input checked="" type="checkbox"/> 168 h <input type="checkbox"/> 48 h	P
12.3	IP test (IEC 529)	IP44	P
	After the test, electric strength test as 13.4, and	IP44	P
	no appreciable entry of water		P

13	INSULATION RESISTANCE AND ELECTRIC STRENGTH		
13.3	Clamping unit connected with: smallest cross-sectional area (mm²); largest cross-sectional area (mm²)	0,75 mm², 1,5 mm²	
	Insulation resistance (500 V d.c. for 1 min):		
	1) between all clamping units connected together and the body > 5 MΩ	>200 MΩ	P
	2) between each clamping unit and all others connected to the body > 5 MΩ	>200 MΩ	P
	3) between metal foil and the body > 5 MΩ		N/A
	3a) if necessary, between live parts and metal covers and enclosures > 5 MΩ		N/A
	3b) if necessary, between live parts and surface on which the base is mounted > 5 MΩ		N/A
13.4	Electric strength (a.c. for 1 min): no flashover or breakdown:		
	1) test voltage (V)	3000 V	P
	2) test voltage (V)	3000 V	P
	3) test voltage (V)		N/A
	3a) test voltage (V)		N/A
	3b) test voltage (V)		N/A

EN 60 998-2-1:2004 and IEC 60 998-2-1:2002			
Cl.	Requirement - Test	Result - Remark	Verdict
14	MECHANICAL STRENGTH		
14.2	Tumbling barrel (for < 50 g): 50 falls; after the test no damage	15 g	P
14.3	Impact test (for > 50 g): 10 blows:		
	- height of fall: 7,5 cm		N/A
	- height of fall: 10 cm		N/A
	- height of fall: 20 cm		N/A
	- height of fall: 25 cm		N/A
	After the test, no damage and live parts shall not become accessible		N/A



15	TEMPERATURE RISE		
	Terminal	<input type="checkbox"/> single <input checked="" type="checkbox"/> multiway	
	T marking (°C).....	<input checked="" type="checkbox"/> Yes 80 (°C):	P
	Largest cross-sectional area (mm²)	1,5	
	Conductors.....	Flexible	P
	Torque (Nm); table number	0,4 Nm	
	Rated connecting capacity (mm²)	1,5 mm²	
	Test current (A)	17,5	
	Temperature rise does not exceed 45 K (1)	25,7	P
	Temperature rise does not exceed 45 K (2)	26,5	P
	Temperature rise does not exceed 45 K (3)	23,3	P

16	RESISTANCE TO HEAT		
16.2	Heating cabinet: no damage, after the test, markings still legible; test temperature (°C)	<input type="checkbox"/> 85 °C <input checked="" type="checkbox"/> T + 45 °C = 125	P
16.3	Ball-pressure test (125 °C) for parts necessary to retain current-carrying parts in position	<input checked="" type="checkbox"/> T + 45 °C = 125	P
	Ball-pressure test for parts not necessary to retain current-carrying parts in position; test temperature (°C)	<input checked="" type="checkbox"/> 70 °C <input type="checkbox"/> 40 +	P
	Diameter of impression not exceeding 2 mm	Internal bracket: 1,65 mm Enclosure: 1,13 mm	P



EN 60 998-2-1:2004 and IEC 60 998-2-1:2002			
Cl.	Requirement - Test	Result - Remark	Verdict
17	CREEPAGE DISTANCES, CLEARANCES AND DISTANCES THROUGH SEALING COMPOUND		
	Creepage distances (mm) and clearances (mm) between live parts of different polarity	cl. and cr. > 5,0 mm	
	idem, requirement (mm)	4,0 mm	P
	Creepage distances (mm) and clearances (mm) between live parts and metal covers and enclosures.....		
	idem, requirement (mm)		N/A
	Creepage distances (mm) and clearances (mm) between live parts and surface on which the base is mounted	cl. and cr. > 5,0 mm	
	idem, requirement (mm)	4,0 mm	P
	Distances (mm) through sealing compound between live parts and surface on which the base is mounted		
	idem, requirement (mm)		N/A
18	RESISTANCE OF INSULATING MATERIAL TO ABNORMAL HEAT AND FIRE		
	Glow-wire test (850 °C) for parts necessary to retain current-carrying parts in position		P
	Glow-wire test (650 °C) for parts not necessary to retain current-carrying parts in position		P
	No visible flames and no sustained glowing, or if flame and glowing, extinguish within 30 s.....		P
	No ignition of the tissue paper or scorching of the board		P
19	RESISTANCE OF INSULATING MATERIAL TO TRACKING		
	50 drops, 175 V, solution A (IEC 112): no flashover		P

Photo:


Whole unit of L656



Internal view of L656



Terminal



---End of report---